


## **iSMA-B-AAC20-LCD**



| SPECIFICATION      |   |
|--------------------|---|
| Supply             | DC: 24 V ± 20%, 5 W; AC: 24 V ± 20%, 7.5 VA                               |
| Universal inputs   | 8 - voltage, current, resistance and temperature measurement, dry contact |
| Digital inputs     | 4 - dry contact input, high-speed pulse counter up to 100 Hz              |
| Digital outputs    | 4 - relay output;   |
|                    | Resistive load max. 3 A @ 230 V AC, 3 A @ 30 V DC                         |
|                    | Inductive load max. 75 VA @ 230 V AC, 30 W @ 30 V DC                      |
| Analog outputs     | 6 - 0-10 V DC output, maximum load up to 20 mA (A6 up to 5 mA)            |
| Processor          | Cortex M4 + M0 (204 MHz), Sedona Virtual Machine 1.2.28                   |
| Interface          | 2 x Ethernet, RS485, Host USB, 1Wire, Display Port                        |
| Ingress Protection | IP40 - for indoor installation  |
| Temperature        | Operating: -10°C do +50°C; Storage -40°C do +85°C                         |
| Relative Humidity  | 5 to 95% RH (without condensation)  |
| Connectors         | Separable 2.5 mm <sup>2</sup>   |
| Dimensions         | 106 x 110 x 62 mm   |
| Mounting           | DIN rail mounting (DIN EN 50022 norm)                                     |
| Housing material   | Plastic, self-extinguishing PC/ABS  |



- correctly wired before turning the power ON.
- Before wiring, or removing/mounting the product, be sure to turn the power OFF. Failure to do so might cause electric shock.
- Do not touch electrically charged parts such as the power terminals. Doing so might cause electric shock.
- · Do not disassemble the product. Doing so might cause electric shock or faulty operation.
- Use the product within the operating ranges recommended in the specification (temperature, humidity, voltage, shock, mounting direction, atmosphere etc.). Failure to do so might cause fire or faulty operation.
- · Firmly tighten the wires to the terminal. Insufficient tightening of the wires to the terminal might cause fire.

